DRAWING CHANGES					
REV	ECN NO	DESCRIPTION	BY	CKD	DATE

TANK WEIGHT:
DRY WEIGHT: 250L – 60kg
315L – 72kg
WET WEIGHT: 250L – 310kg
315L – 385kg

SYSTEM WEIGHT:
DRY WEIGHT: 250L – 268kg
315L – 280kg
WET WEIGHT: 250L – 518kg
315L – 593kg

PRIMARY PUMP:

DD5: 2xGRUNDFOS
UPS32–100N

HD210 HEATERS:

SYSTEM GAS LOAD: 1050MJ
–NG 1.13–3.00 kPa
–LPG 2.75–3.00 kPa

THERMOSTAT:


FACTORY SET AT 65°
(HIGHER TEMP AVAILABLE)

GENERAL NOTE:


SYSTEM REQUIRES:
6 X EXTERNAL GPO (10AMP)

** PLEASE NOTE **
DO NOT RUN CONDENSATE DRAIN IN COPPER.
UPVC PIPE IS RECOMMENDED.

ELEVATION VIEW



PLAN VIEW



MATERIAL		DRAWN	RMP	**Rinnai** Australia Pty Ltd
TOLERANCE –UNLESS STATED 0. ±1.0 0.00 ±0.1 0.0 ±0.5 Angular ±1°	DIMINSIONS ARE IN MILLIMETERS AS 1100 THIRD ANGLE PROJECTION	DATE	13/10/20	Title: DDF5210E–250/315N
		CHECKED	SVL	
FINISH:	DO NOT SCALE DRAWING	APPROVED		Weight: SEE NOTES / Drawing Number(PART NO): SK 0160 / Revision: 1