



| DRAWING CHANGES | | | | | |
|-----------------|--------|-------------|----|-----|------|
| REV | ECN NO | DESCRIPTION | BY | CKD | DATE |
| | | | | | |

TANK

DRY WEIGHT: 250L - 60kg
315L - 72kg

WET WEIGHT: 250L - 310kg
315L - 385kg

SYSTEM WEIGHT: 175kg

HD200 HEATERS:
GAS LOAD EACH 200MJ
- NG 1.13 - 2.75 kPa
- LPG 2.75 kPa
FAN ASSISTED , BALANCED FLUE
WEIGHT 20kg EACH APPROX

THERMOSTAT:
FACTORY SET AT 65°

PRIMARY PUMP:
DD5: 2xGRUNDFOS UP25-80B
WITH WEATHER PROOF COVER

GENERAL NOTE:
TANK REQUIRES EXTERNAL
GPO. PRIMARY PUMP CONNECTS
INTO TANK GPO.

| | | | | | |
|---------------------------|----------------------|----------|--|-------------------------|----------|
| MATERIAL | DRAWN | DAP | Rinnai Australia Pty Ltd | | |
| TOLERANCE - UNLESS STATED | DATE | 21/05/12 | | | |
| 0.±1.0 0.0 ±0.5 | CHECKED | SVL | Title DEMAND DUO-DD520OE STORAGE HOT WATER | | |
| 0.00 ±0.1 Angular ±1 | APPROVED | | | | |
| FINISH: | DO NOT SCALE DRAWING | | Weight | Drawing Number(PART NO) | Revision |
| | | | | RA-21-05-12-009 | |